



2018 Water Quality Report Roaring Creek Division, PWSID# PA4490024

*Este informe contiene información muy importante sobre su agua potable.
Tradúzcalo ó hable con alguien que lo entienda bien.*

About Your Drinking Water

Aqua Pennsylvania, Inc. (Aqua) is pleased to provide you with important information about your drinking water in this 2018 Consumer Confidence Report for the Roaring Creek Division (public water supply ID# PA4490024). The report summarizes the quality of water Aqua provided in 2018 - including details about water sources, what the water at your tap contains, and how it compares to standards set by regulatory agencies. Although the report lists only those regulated substances that were detected in your water, we test for more than what is reported. This report is only a summary of our testing during 2018. If you have any questions about the information in this report, please call 877.WTR.AQUA (877.987.2782) or visit our website at AquaAmerica.com.

Sources of Supply

Water for the Roaring Creek Division comes from three different surface water sources and two wells. Source Water Assessments for the South Branch of Roaring Creek watershed was completed in 2003 by the Pennsylvania Department of Environmental Protection (DEP). This area includes four reservoirs and two wells which provide water to approximately 43,000 people. The sources overall have a low risk of significant contamination. Information on source water assessments is available on the DEP Web site at www.dep.pa.gov (DEP keyword "source water"). Copies of the complete report are available for review at the DEP North Central Regional Office, Williamsport, PA (570.327.3636).

The sources of drinking water (tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban storm runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and herbicides, which may come from a variety of sources such as agriculture, stormwater runoff, and residential uses.
- Organic chemical contaminants, including synthetic and volatile organics, are byproducts of industrial processes and petroleum production and can also come from gas stations, urban stormwater runoff, and septic systems.
- Radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water, which must provide the same protection for public health.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's (EPA) Safe Drinking Water Hotline at 800.426.4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (800.426.4791).

The following table lists contaminants that were detected in your water system. The table provides the average of the sources used to supply the Division as well as minimum and maximum observed levels of regulated contaminants. Below the table is information on water sources and the municipality served.

Aqua Pennsylvania, Inc., Roaring Creek Division – PWSID# PA4490024

Contaminants	Average Detection	Range of Detections	MCL	MCLG	Sample Date	Violation Y/N	Major Sources in Drinking Water
Turbidity, % meeting	100%	100 - 100%	TT	NA	2018	N	Soil runoff
Values above are % meeting plant performance level. The Treatment Technique requirement is 95% of samples < 0.3 NTU							
Inorganic Contaminants							
Barium, ppm	0.01	0.005 – 0.02	2	2	2018	N	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits
Chromium, ppb	1	ND - 2	100	100	2018	N	Discharge from steel and pulp mills; Erosion of natural deposits
Disinfectants and Disinfection By-products - For haloacetic acids and total trihalomethanes, compliance is based on a running annual average of quarterly test results, not a single sample result.							
Haloacetic acids, ppb	43	ND - 155	60	NA	2018	N	Byproduct of drinking water chlorination
Total Trihalo-methanes, ppb	38	3 - 163	80	NA	2018	N	
Chlorite, ppm (distribution point)	0.42	0.11 - 0.73	1	0.8	2018	N	
Chlorite, ppm (entry point)	0.25	ND – 0.7	1	0.8	2018	N	
Disinfectant Residual – Values below reflect results from routine monthly distribution sampling at multiple sites.							
Chlorine, ppm	1.2	0.2 – 3	MRDL =4	MRDLG =4	2018	N	Water Additive used to control microbes

Contaminants	Entry Point #	Minimum Disinfectant Residual	Lowest Level Detected	Range of Detections	Sample Date	Violation Y/N	Major Sources in Drinking Water
Entry Point Disinfectant Residual – PA Ground Water Rule: This rule requires that no well station operate below specific minimum free chlorine levels for more than 4 hours.							
Chlorine, ppm	101	0.4	0.9	0.9 – 2.6	2018	N	Water additive used to control microbes
	102	0.2	1.0	1.0 – 3.6	2018	N	
**Chlorine dioxide, ppm	102	0.2	ND	ND – 0.1	2018	N	

*Disinfectant levels did not drop below minimum residual level required for more than 4 hours.

**Chlorine dioxide is infrequently used.

Total Organic Carbon (TOC)- 2018					
Contaminant	Range of % Removal Required	Range of percent removal achieved	Number of quarters out of compliance	Violation Y/N	Sources of Contamination
TOC	35	8 - 60	0	N	Naturally present in the environment

Lead and Copper	90th Percentile	Total Number of Samples	Samples Exceeding Action Level	Action Level	MCLG	Sample Date	Violation Y/N	Major Sources in Drinking Water
Copper, ppm	0.07	30	0	AL= 1.3	1.3	2016	N	Corrosion of household plumbing
Lead, ppb	4.6	30	0	AL= 15	0	2016	N	

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Aqua is responsible for providing high quality drinking water but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your cold water tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

The 1996 amendments to the Safe Drinking Water Act (SDWA) require that once every 5 years, the U.S. Environmental Protection Agency (EPA) issue a new list of no more than 30 unregulated contaminants to be monitored by public water systems (PWS). The Unregulated Contaminant Monitoring Rule (UCMR) provides EPA and other interested parties with scientifically valid data on the occurrence of contaminants in drinking water. These data serve as a primary source of occurrence and exposure information that the agency uses to develop regulatory decisions. If a PWS monitoring for UCMR4 finds contaminants in its drinking water, it must provide the information to its customers in this annual water quality report. Below is a table of the results of our UCMR4 monitoring in 2018. All other contaminants tested during UCMR4 were Not Detected.

Unregulated Contaminants Detected During 2018			
Unregulated Contaminant	Average Detection	Range of Detections	MCL
Raw Samples (untreated)			
Total Organic Carbon, ppb	3115	1860 - 5130	NA
Entry Point Samples			
Manganese, ppb	10.7	1.1 – 53.3	NA
Distribution Samples			
Bromochloroacetic acid, ppb	1.9	0.3 – 4.6	NA
Bromodichloroacetic acid, ppb	1.3	ND – 4.3	NA
Chlorodibromoacetic acid	ND	ND – 0.9	NA
Dibromoacetic acid, ppb	ND	ND – 1.1	NA
Dichloroacetic acid, ppb	28.0	1.1 – 76.2	NA
Monochloroacetic acid, ppb	2.3	ND – 6.7	NA
Trichloroacetic acid, ppb	31.2	ND – 73.4	NA

Water Sources: Three man-made reservoirs on the South Branch of Roaring Creek and two wells

Municipalities served: Columbia County: Conyngham Township, Borough of Centralia
Northumberland County: City of Shamokin, Coal Township, Mt. Carmel Township, Ralpho Township, Shamokin Township, Zerbe Township, Borough of Mt. Carmel, Borough of Kulpmont, Borough of Marion Heights. Schuylkill County: Butler Township, Borough of Girardville, Borough of Gordon, Borough of Ashland

Notes:

Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements.

Fluoride: Fluoride may help prevent tooth decay if administered properly to children, but can be harmful in excess. Customers in the Roaring Creek system receive water from unfluoridated supplies.

Maximum Contaminant Level (MCL): The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG): The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

NA: Not applicable. **ND:** Not detected.

NTU: Nephelometric turbidity unit (cloudiness of water)

ppb: A unit of concentration equal to one part per billion.

ppm: A unit of concentration equal to one part per million.

PWSID: Public water supply identification number.

Turbidity: Monitored as a measure of treatment efficiency for removal of particles.

Treatment Technique (TT): A required process to reduce the level of a contaminant in drinking water.

Our water systems are designed and operated to deliver water to our customers' plumbing systems that complies with state and federal drinking water standards. This water is disinfected using chlorine, but it is not necessarily sterile. Customers' plumbing, including treatment devices, might remove, introduce or increase contaminants in tap water. All customers, and in particular operators of facilities like hotels and institutions serving susceptible populations (like hospitals and nursing homes), should properly operate and maintain the plumbing systems in these facilities. You can obtain additional information from the EPA's Safe Drinking Water Hotline at 800.426.4791.